



भरतपुर महानगरपालिका
नगर कार्यपालिकाको कार्यालय
भरतपुर, चितवन, नेपाल
BHARATPUR METROPOLITAN CITY
Office of Municipal Executive
Bharatpur, Chitwan, Nepal



प.सं. २०८२/०८३
च.नं. १४९४

मिति: २०८२/१२/२५

श्री जो सँग सम्बन्धित छ।

विषय: दररेट पेश गर्ने सम्बन्धमा।

प्रस्तुत विषयमा यस भरतपुर महानगरपालिकाको आ.व. २०८२/०८३ को आर्थिक विकास महाशाखाको कृषि शाखाबाट संचालन हुने बोरिङ्ग निर्माण कार्यको लागि दररेट कायम गर्नु परेको ले सम्बन्धित फर्म, सप्लायर्स वा वितरक कम्पनीहरूले यसै अनुसार स्पेसिफिकेसन सहितको तपसिल बमोजिमको सामग्री/कार्यहरूको हालको दररेट लिखित रुपमा ७ (सात) दिन भित्र यस भरतपुर महानगरपालिकाको कृषि शाखामा उपलब्ध गराईदिनुहुन अनुरोध छ।


तपसिल :

SN	Description of works	Unit	Offered Rate without VAT	Remarks
A.	Construction of 6" dia. (42m depth) submersible Tube well			
1	Drilling of Tubewell by standard dia. Bit (DTH Method) all complete.	meter		
2	Drilling of pilot hole by standard dia. (Percussion Method) all complete	meter		
3	Reaming and reconditioning of pilot hole by standard dia. Bit	meter		
4	Tochan wire for pump support	meter		
5	Lowering of pipe assembly including welding water tight all complete	meter		
6	Well Development by compressor	Hr.		
7	MS casing pipe 6" NB as per IS:3589/IS:4270	kg		
8	MS screen making Charge	meter		
9	Supply and Installation of casing shoe all complete	Set		
10.	MS Flange 8 inch dia.(well cap) set	No.		
11	Supply & Installation of Submersible pump for a discharge capacity of not less than 10 LPS and a total head range of 40-65 meters, with a 3-inch outlet and an overall efficiency of 60-70%, suitable for installation in a 6-inch well. It is powered by a not less than 7.5 HP water-filled submersible motor operating at 400 V (+6%, -10%) and 50 Hz, built for continuous duty with a star-delta starting method, and meets IS 8034:2002 and IS 9283:1995 standards or their equivalent.	Set		
12	90mm OD NS 206/046-UPVC Column pipe not less than 10kgf/cm ² Pressure	R.meter		
13	GI elbow @3" diameter NS/ISI	Pcs		
14	4.0 sq.mm Submersible 3 core flat flexible copper wire cable, IS/ ISO certified	meter		
15	Supply of DOL plain Board of 3 phase electric Motor Stater 7.5Hp and control panel setup (Bentax or Equivalent)	Set		
16	Time Drawdown Pump Test	Hr.		

056-520167, 521467, 530062, 526951, 522252, Fax: 056-520014

E-mail: bmc@ntc.net.np / website: bharatpurmun.gov.np

भरतपुर महानगरपालिकाको कार्यालय, चितवन, नेपाल



भरतपुर महानगरपालिका
नगर कार्यपालिकाको कार्यालय
भरतपुर, चितवन, नेपाल
BHARATPUR METROPOLITAN CITY
Office of Municipal Executive



Bharatpur, Chitwan, Nepal

17	Report Preparation including general characteristics of well & compilation with complete details of lithological data, well design, pump test with complete analysis	1 well		
B.	Construction of shallow Tubewell			
18	Drilling Charge 4" NB mechanically	R.m		
19	2H.P electric Motor Pump Set: IS/ISO certified 2HP monoblock water pump discharge at least 8l/s, single phase, 3 inch delivery with GI bend complete all set	Set		
20	2HP electrical submersible pump, IS/ISO certified, single phase, head range $\geq 20m$, discharge $\geq 8l/s$, 3inch delivery all set	Set		
21	3" Check Valve (Non return Valve)	pcs		
22	GI elbow @3" diameter medium	pcs		
23	3" suction hose pipe for agriculture medium duty	rm		
24	Delivery Pipe, LDPE material, thickness not less than 3mm of pressure not less than 6kg/cm ²	kg		specify kg into meter
25	Foot Valve, 3"	set		
26	CI Heavy Pump	Set		

तेजेन्द्र प्रसाद पौडेल
आर्थिक विकास महाशाखा प्रमुख

महाशाखा प्रमुख

आवश्यक कागजातहरू:

१. फर्म दर्ता प्रमाणपत्र तथा कर चुक्ता प्रमाणपत्रको प्रतिलिपि।
२. भ्याट दर्ता प्रमाणपत्रको प्रतिलिपि/पान।
३. फर्मको लेटरहेडमा हालको बजार दरभाउ सहितको निवेदन।